

IEC 61850 Certificate - IEC 61850 Certificate #2802

UT-0221 Smart prevent mal-operation devi [ZHUHAI UNITECH POWER TECHNOLOGY]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2018PUCA001
61850 Edition:	Edition 1	Certificate Hash:	48F4119E2F18095C9E26FCE2A969539 0C31617B912B178F69D4EF5532D36B 090
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZHUHAI UNITECH POWER TECHNOLOGY	Vendor Artifact Hash:	
Address:	No.102,Yinhua Road,Xiangzhou,Zhuhai City,Guangdong Province,P.R.China	Umbrella Organization:	
Product:	UT-0221 Smart prevent mal-operation devi	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.00.00.00	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/25/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File Zhuhai Unitech Power Technology Co.Ltd._ UT-0221 Smart prevent mal-ope added

Files

Zhuhai Unitech Power Technology Co.Ltd._ UT-0221 Smart prevent mal-operation devi 07/08/2021 00.00_2018PUCA0001_KETOP.pdf Herbert Falk