

IEC 61850 Certificate - IEC 61850 Certificate #2803

ZLV - DISTANCE PROTECTION RELAY [ZIV Automation India Pvt Ltd.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Test Document:
61850 Tested Aspects:	Server	Certificate Name: CPRIBLRMUADSASLI9TCOOOI
Company:	ZIV Automation India Pvt Ltd.	Certificate Hash: EB86D0355D7A2EC10D9C53297228B2633A9834F611B93325699B9067F34720AF
Address:	Global Village Tech Park, DRC Building, Ground Floor, RVCE Post, Mylasandra, Bangalore - 560059, INDIA	Vendor Artifact File Name:
Product:	ZLV - DISTANCE PROTECTION RELAY	Vendor Artifact Hash:
HW Version:	8ZLV-F4F-2C02H82NL	Umbrella Organization:
SW Version:	04.03.06	Optional Reservation Test: No
Key Words:	Distance, Protection, Relay	Serial Number:
Test Procedure Version:	3.2	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	02/11/2019	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	Central Power Research Institute India (A)	Subscriber Preferred Rates:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File ZIV_ZLV_CPRIBLRMUADSASLI9TC0001.pdf added

Files

ZIV_ZLV_CPRIBLRMUADSASLI9TC0001.pdf	832 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------