

IEC 61850 Certificate - IEC 61850 Certificate #2804

!DV - DIFFERENTIAL PROTECTION RELAY [ZIV Automation India Pvt Ltd.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASLI9TC0002
61850 Edition:	Edition 1	Certificate Hash:	738D59AAE78364D9AD55DB0245A2A5 95B071406632B2B0FCD0A6C82488369 859
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZIV Automation India Pvt Ltd.	Vendor Artifact Hash:	
Address:	Global Village Tech Park, DRC Building, Ground Floor, RVCE Post, Mylasandra, Bangalore - 560059, INDIA	Umbrella Organization:	
Product:	!DV - DIFFERENTIAL PROTECTION RELAY	Optional Reservation Test:	No
HW Version:	8!DV-L4F-2DOEF8QNL	Serial Number:	
SW Version:	04.03.06	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/11/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File ZIV_IDV_CPRIBLRMUADSASLI9TC0002.pdf added

Files

ZIV_IDV_CPRIBLRMUADSASLI9TC0002.pdf	829 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------