

# IEC 61850 Certificate - IEC 61850 Certificate #2805

## IRV - Multifunction Feeder Protection [ZIV Automation India Pvt Ltd.]

07/08/2021 04:55 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	CPRIBLRMUADSASL19TC0003
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	89AA451E29F58F8C73C3715750EC27 DBFE51528CF68CC1BFA48EE0EA3F6 937F7
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	ZIV Automation India Pvt Ltd.	<b>Umbrella Organization:</b>	
<b>Address:</b>	Global Village Tech Park, DRC Building, Ground Floor, RVCE Post, Mylasandra, Bangalore - 560059, INDIA	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	IRV - Multifunction Feeder Protection	<b>Serial Number:</b>	
<b>HW Version:</b>	7IRV-M4F-230RF8QNM	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	04.03.06	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	IOC, Protection, Relay, TOC	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	3.2	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	02/11/2019	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File ZIV\_IRV\_CPRIBLRMUADSASL19TC0003.pdf added

### Files

ZIV\_IRV\_CPRIBLRMUADSASL19TC0003.pdf

818 KB

07/08/2021

Herbert Falk