IEC 61850 Certificate - IEC 61850 Certificate #2806

YS-411 HVDC AC Filter Protection IED [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	19-003457-01-1
61850 Tested Aspects:	Server	**Certificate Hash:**	EB5D7B3441255BD18C251B7A7B5587CC514F22B03A41C3F9A1987DFFD85C9726
Company:	YOUSUNG Instrument & Electric Co., Ltd.	**Vendor Artifact File Name:**	
Address:	76, Gaetbeol-ro (Songdo-dong), Yeonsu-gu, Incheon, Republic of Korea, 21999	**Vendor Artifact Hash:**	
Product:	YS-411 HVDC AC Filter Protection IED	**Umbrella Organization:**	
HW Version:	YSIED with Linux	**Optional Reservation Test:**	No
SW Version:	1.0	**Serial Number:**	
Key Words:	Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	3.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	02/18/2019	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	Korea Testing Laboratory (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File 19-003457-01-1_YOUSUNG_YS-411_Server_Ed1_Certification_KTL.pdf added

Files

19-003457-01-1_YOUSUNG_YS-411_Server_Ed1_Certification_KTL.pdf	11 KB	07/08/2021	Herbert Falk