

# IEC 61850 Certificate - IEC 61850 Certificate #2815

## Easergy P5F30 Feeder Protection [Schneider Electric Industries SAS]

07/08/2021 04:55 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 089191 0021 Rev. 00
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	E5AF3D0C6499BF8F89B0482B464227 8FCDE699CC339F467E1F223288F37A 0347
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	35 rue Joseph Monier 92500 Rueil-Malmaison, France	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Easergy P5F30 Feeder Protection	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	V01	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	IOC, Protection, Relay, TOC	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/18/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#### #1 - 07/08/2021 04:55 PM - Herbert Falk

- File 19-D 089191 0021 Rev. 00-Schneider Electric\_P5F30\_IEC61850Ed1-Server-C added

#### #2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#### #3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#### #4 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

**Files**

19-D 089191 0021 Rev. 00-Schneider Electric\_P5F30\_IEC61850Ed1-5-2018 Certificate 07/18/2021

Herbert Falk