

IEC 61850 Certificate - IEC 61850 Certificate #2818

PCS-9611 FEEDER RELAY [NR Electric Co., Ltd.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Certificate Name:	D 061589 0137 Rev. 00
Priority:	Normal	Certificate Hash:	3765F36DF04ECCE84065314F0E0D32 DE67BFFA568869F4F88C204710014C A5B9
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NR Electric Co., Ltd.	Umbrella Organization:	
Address:	69 Suyuan Avenue 211102 Nanjing China	Optional Reservation Test:	No
Product:	PCS-9611 FEEDER RELAY	Serial Number:	
HW Version:	NR4106	Publisher Legacy Variants:	
SW Version:	Ed2 1.00	Publisher Preferred Rates:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	03/18/2019	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File 19-D 061589 0137 Rev. 00-NR Electric_PCS-9611_PCS-9000 variants_IEC618 added

Files

19-D 061589 0137 Rev. 00-NR Electric_PCS-9611_PCS-9000 variants_3506850Ed2-57062021 certificate.pdf

Herbert Falk