

IEC 61850 Certificate - IEC 61850 Certificate #2821

Falcon Partial Discharge Analyzer [TECHIMP - Altanova Group S.r.l.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 103727 0001 Rev00 A
61850 Edition:	Edition 1	Certificate Hash:	35C35B77057355B77EBC156688E9B4 F8A9CA35C9BC160CB892A09CE1A40 E1400
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TECHIMP - Altanova Group S.r.l.	Vendor Artifact Hash:	
Address:	Via Toscana 11/C 40069 Zola Predosa Italy	Umbrella Organization:	
Product:	Falcon Partial Discharge Analyzer	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.1.0	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/20/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File UCA-ZE 18 103727 0001 Rev00 A_Techimp_FALCON_IEC61850Ed1-Server-Certif added

#2 - 07/11/2021 11:24 AM - Herbert Falk

- File UCA-ZE 18 103727 0001 Rev00 A_Techimp_FALCON_IEC61850Ed1-Server-Certificate.pdf added

- Address updated

#3 - 07/11/2021 11:24 AM - Herbert Falk

- File deleted (UCA-ZE 18 103727 0001 Rev00 A_Techimp_FALCON_IEC61850Ed1-Server-Certif)

Files

UCA-ZE 18 103727 0001 Rev00 A_Techimp_FALCON_IEC61850Ed1-Server-Certificate.pdf 07/11/2021

Herbert Falk