

IEC 61850 Certificate - IEC 61850 Certificate #2824

Smart Process Controller SA Local Inform [WOODAM TECH CO., LTD.]

07/08/2021 04:55 PM - Herbert Falk

| | | | |
|-------------------------------------|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 19-001003-04-5 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 3A88443676DE7E736F2857845A34CFA D8478CB309F46FEC21865246A946E2 5C6 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | WOODAM TECH CO., LTD. | Vendor Artifact Hash: | |
| Address: | 211 Techno-zone, 117 Hwanggeum-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea, 10048 | Umbrella Organization: | |
| Product: | Smart Process Controller SA Local Inform | Optional Reservation Test: | No |
| HW Version: | AVDANTECH ECU-4784 Win Sr 2012R2 | Serial Number: | |
| SW Version: | 1.0 | Publisher Legacy Variants: | |
| Key Words: | Measurement, RTU | Publisher Preferred Rates: | |
| Test Procedure Version: | 3.2 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 03/20/2019 | | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | Korea Testing Laboratory (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File 19-001003-04-5_WOODAM_SPC_Server_Ed1_Certification_KTL.pdf added

Files

| | | | |
|--|--------|------------|--------------|
| 19-001003-04-5_WOODAM_SPC_Server_Ed1_Certification_KTL.pdf | 112 KB | 07/08/2021 | Herbert Falk |
|--|--------|------------|--------------|