

IEC 61850 Certificate - IEC 61850 Certificate #2825

HPCi High Performance Controller [GE Power Conversion]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Certificate Name:	10060939-INC 19-2030
Priority:	Normal	Certificate Hash:	66FB5CF6E5F51172344DBD6B7B82B9 211413251390BD4BBC0E686FB41A40 36B5
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	GE Power Conversion	Umbrella Organization:	
Address:	18 Avenue de Quebec 91140 Villebon-sur-Yvette France	Optional Reservation Test:	No
Product:	HPCi High Performance Controller	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	61850 Firmware: V4.1.2	Publisher Preferred Rates:	
Key Words:	Bay Controller	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	03/27/2019	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File 19-2030_DNVGL_GE_HPCi_ServerEd2_Certificate.pdf added

Files

19-2030_DNVGL_GE_HPCi_ServerEd2_Certificate.pdf	134 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------