

# IEC 61850 Certificate - IEC 61850 Certificate #2826

## SE Service (Smart Energy Service) [ICPSI (Intelligent Cloud Plus)]

07/08/2021 04:55 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	19_01_CAV_011
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	B06B9C2D7C8709DDA3CA41E4023783 509658A307B6841D5CA4070AD5E656 BF31
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	ICPSI (Intelligent Cloud Plus)	<b>Umbrella Organization:</b>	
<b>Address:</b>	14F., No. 55, Zhongzheng 3rd Rd., Xinxing Dist., Kaohsiung City SOO, Taiwan (R.O.C.)	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	SE Service (Smart Energy Service)	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	V1.I SPI	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Comm	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	03/29/2019	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Taiwan Testing and Certification Center (A)		
<b>Test Document:</b>			
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:55 PM - Herbert Falk

- File ICPSI\_IEC 61850Ed2\_CT-Server\_Certificate\_19\_01\_CAV\_011\_2.pdf added

### Files

ICPSI\_IEC 61850Ed2\_CT-Server\_Certificate\_19\_01\_CAV\_011\_2.pdf 1.89 MB

07/08/2021

Herbert Falk