

IEC 61850 Certificate - IEC 61850 Certificate #2827

SUR-K210 [Sanion Co., Ltd.]

07/08/2021 04:55 PM - Herbert Falk

Status:	Approved	Certificate Name:	19TC201306
Priority:	Normal	Certificate Hash:	4DEC8D64FF1B79F5B51827F428B769 D7CC6BC216A707FE73F92188B70E7C CB6E
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Sanion Co., Ltd.	Umbrella Organization:	
Address:	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	Optional Reservation Test:	No
Product:	SUR-K210	Serial Number:	
HW Version:	1.0	Publisher Legacy Variants:	
SW Version:	FW: 1.0; MPU:1.0; DSP:1.0	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	3.2	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Product Variants:	
Approval Date:	03/29/2019		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File RT18B01425_Sanion_SUR-K210_Server_Ed1_KERI.pdf added

Files

RT18B01425_Sanion_SUR-K210_Server_Ed1_KERI.pdf	914 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------