

# IEC 61850 Certificate - IEC 61850 Certificate #2828

## SICAM P850 Power Meter [Siemens AG]

07/08/2021 04:56 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10129678-INC 19-2301
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	F0168259162E198AEA91321929FAA34 4217FC3CB40900CE2E8F4A49A491F8 04D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	EM DG SA&P Wernerwerkdammm 5 D-13623 Berlin Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	SICAM P850 Power Meter	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	CC	<b>Serial Number:</b>	
<b>SW Version:</b>	V02.22.01	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Meter	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/08/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2301\_DNVGL\_Siemens\_P850\_ServerEd2\_Certificate.pdf added

### Files

19-2301_DNVGL_Siemens_P850_ServerEd2_Certificate.pdf	125 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------