

IEC 61850 Certificate - IEC 61850 Certificate #2830

SCOPE advanced Automation Mgmt System [SCOPE T&M Pvt. Ltd.]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10127867-INC 19-2456
61850 Tested Aspects:	Client	Certificate Hash: 423E63C192FA315769C2F98953003947E6543A4B0DC4A5B90894B0CB65091C17
Company:	SCOPE T&M Pvt. Ltd.	Vendor Artifact File Name:
Address:	EL 31/11, J Block MIDC Bhosari Pune 411026 India	Vendor Artifact Hash:
Product:	SCOPE advanced Automation Mgmt System	Umbrella Organization:
HW Version:	Avell Titanium G1555 Iron v4	Optional Reservation Test: Yes
SW Version:	an-2016.2.95	Serial Number:
Key Words:	Comm	Publisher Legacy Variants:
Test Procedure Version:	1.1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	05/06/2019	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2456_DNVGL_SCOPE_ActionNET_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:12 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

19-2456_DNVGL_SCOPE_ActionNET_ClientEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------