IEC 61850 Certificate - IEC 61850 Certificate #2832

zenon Supervisor/Energy Edition [Ing. Punzenberger COPA-DATA GmbH]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10142640-INC 19-2325
61850 Tested Aspects:	Client	**Certificate Hash:**	2752F445A631757B9EB31F10BCE96FD6C46F9DDF07410974B68331088C20F975
Company:	Ing. Punzenberger COPA-DATA GmbH	**Vendor Artifact File Name:**	
Address:	Karolingerstr. 7B 5020, Salzburg Austria	**Vendor Artifact Hash:**	
Product:	zenon Supervisor/Energy Edition	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	Yes
SW Version:	8.00	**Serial Number:**	
Key Words:	Comm, HMI	**Publisher Legacy Variants:**	
Test Procedure Version:	1.1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	05/08/2019	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2325_DNV_GL_COPADATA_ZENON_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:13 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

19-2325_DNV_GL_COPADATA_ZENON_ClientEd2_Certificate.pdf	125 KB	07/08/2021	Herbert Falk