

IEC 61850 Certificate - IEC 61850 Certificate #2833

DW-IPC-11000 Substation Automation Infor [Dowoo Digitech]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19-007156-02-5
61850 Edition:	Edition 1	Certificate Hash:	D87B6E1A71A12557088BB5BF7A060A 8C02267D6BFD2E0187F6FAB41596A1 9CD5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Dowoo Digitech	Vendor Artifact Hash:	
Address:	A-708, Ssangyong IT Twin Tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea, 13216	Umbrella Organization:	
Product:	DW-IPC-11000 Substation Automation Infor	Optional Reservation Test:	No
HW Version:	Windows Server 2012 R2	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm, RTU	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/10/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-007156-02-5_DOWOO_DW-IPC-11000_Server_Ed1_Certification_KTL.pdf added

Files

19-007156-02-5_DOWOO_DW-IPC-11000_Server_Ed1_Certification_KTL.pdf

07/08/2021

Herbert Falk