

IEC 61850 Certificate - IEC 61850 Certificate #2834

ETR600-BC Protection and Control Device [ENTEC Electric & Electronic Co., Ltd.]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19TC201201
61850 Edition:	Edition 1	Certificate Hash:	5EE910EE72968476AC678AEC4EBD25 DA88AFCE52BDB27296B36D07D7365 B529E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ENTEC Electric & Electronic Co., Ltd.	Vendor Artifact Hash:	
Address:	225-38 Choirubaekro, Bongdam-eup, Hwasung-city Gyeonggido, 445-894 Republic of Korea	Umbrella Organization:	
Product:	ETR600-BC Protection and Control Device	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	MPU1.0.0.0,DSP1.0.1.1,CPU1.2.0.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/13/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/10/2021 01:37 PM - Herbert Falk

- File 19TC201201_Entec_ETR600BC_Server_Ed1_KERI.pdf added

- Address updated

Files

19TC201201_Entec_ETR600BC_Server_Ed1_KERI.pdf

6.5 MB

07/10/2021

Herbert Falk