

IEC 61850 Certificate - IEC 61850 Certificate #2835

Elipse Power IEC 61850 client driver [Elipse Software, Ltda]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10147432-INC 19-2400
61850 Edition:	Edition 2	Certificate Hash:	C57914136B112080AF144554B0BF8FC DE553B0655B1967C6B89C6E2B2D50B F82
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Elipse Software, Ltda	Vendor Artifact Hash:	
Address:	Rua 24 de Outubro 353 - 10 Andar 90510-002 Porto Alegre RS - Brasil	Umbrella Organization:	
Product:	Elipse Power IEC 61850 client driver	Optional Reservation Test:	Yes
HW Version:	Ideapad 320 with Win 10 Enterpri	Serial Number:	
SW Version:	3.0.1	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/14/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2400_DNVGL_Elipse_Power_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:13 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

19-2400_DNVGL_Elipse_Power_ClientEd2_Certificate.pdf	125 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------