

# IEC 61850 Certificate - IEC 61850 Certificate #2836

## Easergy P5U20 Universal Current Protecti [Schneider Electric Industries SAS]

07/08/2021 04:56 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	SchneiderElectric_Easergy_P5U20_V01
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	7B7817DEAE2A99D186EF320B8FD2B6 232605D53B92E937743371DE5F2DA00 A17
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	35 rue Joseph Monier 92500 Rueil-Malmaison, France	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Easergy P5U20 Universal Current Protecti	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	V01	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/15/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File SchneiderElectric\_Easergy\_P5U20\_V01\_ServerEd2\_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#4 - 07/09/2021 09:11 AM - Herbert Falk

**Files**

---

SchneiderElectric_Easergy_P5U20_V01_ServerEd2_Certificate.pdf	167 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------