

IEC 61850 Certificate - IEC 61850 Certificate #2840

TR-3000 Multi-Function Recorder [Ametek Power Instruments]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10147682-INC 19-2436
61850 Edition:	Edition 2	Certificate Hash:	9A2C6F7C0B538AC89AA6DF6E965FB FAF5DAFBC98FD33CA783A4BC56FEF AF7ECF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Ametek Power Instruments	Vendor Artifact Hash:	
Address:	255 North Union Street Rochester, NY 14605 USA	Umbrella Organization:	
Product:	TR-3000 Multi-Function Recorder	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.0.0	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/29/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2436_DNVGL_Ametek_TR3000_ServerEd2_Certificate.pdf added

Files

19-2436_DNVGL_Ametek_TR3000_ServerEd2_Certificate.pdf	112 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------