

IEC 61850 Certificate - IEC 61850 Certificate #2842

MiCOM P139 Feeder Management and Bay Con [Schneider Electric Industries SAS]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 089191 0023 Rev. 00
61850 Edition:	Edition 2	Certificate Hash:	F4AB9B4C54FEA3D6979914060AECA8 2A92894E3A88F875ED261264B042EA1 973
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider Electric
Product:	MiCOM P139 Feeder Management and Bay Con	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	670-253	Publisher Legacy Variants:	
Key Words:	Bay Controller, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/10/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-D 089191 0023 Rev. 00-SchneiderElectric_MiCOM P139_IEC61850Ed2-Serv added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#4 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#5 - 07/11/2021 11:20 AM - Herbert Falk

- File 19-D 089191 0023 Rev. 00-SchneiderElectric_MiCOM P139_IEC61850Ed2-Server.pdf added

- Address updated

#6 - 07/11/2021 11:20 AM - Herbert Falk

- File deleted (19-D 089191 0023 Rev. 00-SchneiderElectric_MiCOM P139_IEC61850Ed2-Serv)

Files

19-D 089191 0023 Rev. 00-SchneiderElectric_MiCOM P139_IEC61850Ed2-Server.pdf 07/11/2021

Herbert Falk