

IEC 61850 Certificate - IEC 61850 Certificate #2844

MiCOM P638 Transformer Differential Prot [Schneider Electric Industries SAS]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	SchneiderElectric_MiCOM_P638_661-25
61850 Edition:	Edition 2	Certificate Hash:	69A1E901782862B3761049F20223840D85846B35802200A023391E8F490E3ABF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider Electric
Product:	MiCOM P638 Transformer Differential Prot	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	661-250	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/21/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File SchneiderElectric_MiCOM_P638-661-250_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#4 - 07/09/2021 09:11 AM - Herbert Falk

Files

SchneiderElectric_MiCOM_P638-661-250_ServerEd2_Certificate.pdf 89.1 KB	07/08/2021	Herbert Falk
--	------------	--------------