

IEC 61850 Certificate - IEC 61850 Certificate #2847

SPIN-SD2 Network Monitoring & Diagnosis [Daewoong Electric Co. Ltd.]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19TC201390
61850 Edition:	Edition 1	Certificate Hash:	8CA124E65BAC53A358C4133076AF44 7158978580E075D15E7D1696A6B38B1 87A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Daewoong Electric Co. Ltd.	Vendor Artifact Hash:	
Address:	10, Hwanggeum-ro 127beon-gil, Yangchon-eup. Gimpo-si, Gyeonggi-do, Republic of Korea, 10048	Umbrella Organization:	
Product:	SPIN-SD2 Network Monitoring & Diagnosis	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/26/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19TC201390_Daewoong_SPiN-SD2_Server_Ed1_KERI.pdf added

Files

19TC201390_Daewoong_SPiN-SD2_Server_Ed1_KERI.pdf	347 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------