

IEC 61850 Certificate - IEC 61850 Certificate #2848

KEDR-2.0 (????-2.0) Powerline Communicat [URALENERGOSERVICE LLC]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10157892-INC 19-2552
61850 Edition:	Edition 2	Certificate Hash:	4B6EE09C697E0DA3085EF6E037A187 0F22A61B1EDE565405A9DAD0BB80F DCC45
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	URALENERGOSERVICE LLC	Vendor Artifact Hash:	
Address:	Moskovskiy trakt 8 km, building 14/1 620043, Yekaterinburg Russian Federation	Umbrella Organization:	
Product:	KEDR-2.0 (????-2.0) Powerline Communicat	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	VD2001R	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/27/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2552_DNVGL_URALENERGOSERVICE LLC_KEDR-2.0_ServerEd2_Certificate.pdf added

Files

19-2552_DNVGL_URALENERGOSERVICE LLC_KEDR-2.0_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk