

IEC 61850 Certificate - IEC 61850 Certificate #2850

GRT200 Transformer Protection [TOSHIBA Corporation]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10157263-INC 19-2572
61850 Edition:	Edition 2	Certificate Hash:	CAB16541753FB885551EDDEEA48A21 01A19F07EAB1B793B0B2AE973C2D4B 0CA8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TOSHIBA Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-shi, Tokyo, 183-8511 Japan	Umbrella Organization:	
Product:	GRT200 Transformer Protection	Optional Reservation Test:	No
HW Version:	GRT200-31-224-00-4L-30-111	Serial Number:	
SW Version:	GS2RTIM13017 and 61850:G2M85002A	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/08/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2572_DNVGL_TOSHIBA_GRT200_ServerEd2_Certificate.pdf added

Files

19-2572_DNVGL_TOSHIBA_GRT200_ServerEd2_Certificate.pdf	120 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------