

# IEC 61850 Certificate - IEC 61850 Certificate #2852

## G5 Digital Fault Recorder [Elspec Engineering Ltd.]

07/08/2021 04:56 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10159553-INC 19-2636
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	F683EE57833CC471ECE624A421A692 03CD3213F843710A6ABD8B77FCA599 885B
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Elspec Engineering Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	4 Hashoham St. Zone 23 Caesarea Industrial Park 3088900 Israel	<b>Umbrella Organization:</b>	
<b>Product:</b>	G5 Digital Fault Recorder	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.0.2.14	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Measurement	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/08/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2636\_DNVGL\_ELSPEC\_G5\_ServerEd2\_Certificate.pdf added

### Files

19-2636_DNVGL_ELSPEC_G5_ServerEd2_Certificate.pdf	114 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------