

IEC 61850 Certificate - IEC 61850 Certificate #2855

SIMATIC WinCC Open Architecture [ETM Professional Control GmbH]

07/08/2021 04:56 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10133027-INC 19-2562
61850 Edition:	Edition 1	Certificate Hash:	99802F6924D9CE9A91CCEEA04D2138 D86D2677F47C0C4EB863F9FE64BB69 3A53
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ETM Professional Control GmbH	Vendor Artifact Hash:	
Address:	Marktstrasse 3 7000 Eisenstadt Austria	Umbrella Organization:	
Product:	SIMATIC WinCC Open Architecture	Optional Reservation Test:	No
HW Version:	Fujitsu Celsius W420 Win10 Enter	Serial Number:	
SW Version:	3.16 P012	Publisher Legacy Variants:	
Key Words:	HMI	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/24/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2562_DNV_GL_ETM_WinCC-OA_Windows_ClientEd1_Certificate.pdf added

Files

19-2562_DNV_GL_ETM_WinCC-OA_Windows_ClientEd1_Certificate.pdf 103 KB

07/08/2021

Herbert Falk