

# IEC 61850 Certificate - IEC 61850 Certificate #2856

## SIMATIC WinCC Open Architecture [ETM Professional Control GmbH]

07/08/2021 04:56 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10133027-INC 19-2565
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	0B072CB3ADBA947D389A0E3A7ECFE 2E6080988661B05BB708203662E4549 B3A4
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ETM Professional Control GmbH	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Marktstrasse 3 7000 Eisenstadt Austria	<b>Umbrella Organization:</b>	
<b>Product:</b>	SIMATIC WinCC Open Architecture	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	Celsius W420 CentOS Linux 3.10.0	<b>Serial Number:</b>	
<b>SW Version:</b>	3.16 P012	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	HMI	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/24/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#### #1 - 07/08/2021 04:56 PM - Herbert Falk

- File 19-2565\_DNV\_GL\_ETM\_WinCC-OA\_CentOS\_ClientEd2\_Certificate.pdf added

#### #2 - 07/11/2021 10:14 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

### Files

19-2565\_DNV\_GL\_ETM\_WinCC-OA\_CentOS\_ClientEd2\_Certificate.pdf 16 KB

07/08/2021

Herbert Falk