

IEC 61850 Certificate - IEC 61850 Certificate #2859

GND-Smart-SDP [GENAD SYSTEM Co.]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Test Document:
61850 Tested Aspects:	Client	Certificate Name: 19TC201488
Company:	GENAD SYSTEM Co.	Certificate Hash: 7DCA734402081B2B50B3F5CD68312B83AD6B768E0B8F22CD8C98B6B76A4F04FF
Address:	78, Hyeoksinsandan 5-gil, Naju-si, Jeollanam-do, Republic of Korea	Vendor Artifact File Name:
Product:	GND-Smart-SDP	Vendor Artifact Hash:
HW Version:		Umbrella Organization:
SW Version:	Software: 1.0, Firmware: 1.0	Optional Reservation Test: No
Key Words:	Gateway	Serial Number:
Test Procedure Version:	1.1	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	07/29/2019	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	Subscriber Preferred Rates:
Description		
This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19TC201488_Genadsystem_GND-Smart-SDP_Client_Ed1_KERI.pdf added

Files

19TC201488_Genadsystem_GND-Smart-SDP_Client_Ed1_KERI.pdf	340 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------