

IEC 61850 Certificate - IEC 61850 Certificate #2862

Telem-AGC [Martem AS]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10151005-INC 19-2677
61850 Edition:	Edition 2	Certificate Hash:	37F884342DB33069EB8BBD89AEB48C 23FCAC64F44A698BEA9A67143D75CA 49DF
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Martem AS	Vendor Artifact Hash:	
Address:	Laki 25 12915 Tallinn Estonia	Umbrella Organization:	
Product:	Telem-AGC	Optional Reservation Test:	Yes
HW Version:	AGC-EL-N4-N	Serial Number:	
SW Version:	2.0.126-8C74E1B-K4	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/09/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2677_DNV_GL_Martem_Telem-AGC_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:14 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

19-2677_DNV_GL_Martem_Telem-AGC_ClientEd2_Certificate.pdf	113 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------