

IEC 61850 Certificate - IEC 61850 Certificate #2864

MiCOM AGILE P444 NUMERICAL DISTANCE PROT [GE T&D INDIA LIMITED]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL19TC0004
61850 Edition:	Edition 2	Certificate Hash:	39DC42F7AC62218147EB4CF85B9229 007628C83C0C4DA1C2E8C483D064D8 F2F2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE T&D INDIA LIMITED	Vendor Artifact Hash:	
Address:	19/ 1, G.S.T. Road, Pallavaram, Chennai - 600043 Tamil Nadu, INDIA	Umbrella Organization:	
Product:	MiCOM AGILE P444 NUMERICAL DISTANCE PROT	Optional Reservation Test:	No
HW Version:	P444-M HARDWARE	Serial Number:	
SW Version:	83	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/13/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File CPRI - GE TandD India Ltd - CPRIBLRMUADSASL19TC0004.pdf added

Files

CPRI - GE TandD India Ltd - CPRIBLRMUADSASL19TC0004.pdf	922 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------