

IEC 61850 Certificate - IEC 61850 Certificate #2866

Aegis Transformer Protection Relay [M/s Crompton Greaves Limited]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL19TC0005
61850 Edition:	Edition 1	Certificate Hash:	594C2AAB02620B220FA32CC52622D8 55FBE087D802F55F900346700BDB5D 9705
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s Crompton Greaves Limited	Vendor Artifact Hash:	
Address:	A - 3, MIDC - Ambad, Nashik - 422010 INDIA	Umbrella Organization:	
Product:	Aegis Transformer Protection Relay	Optional Reservation Test:	No
HW Version:	10	Serial Number:	
SW Version:	20-03-10-51	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/26/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File CPRI-CG Power-Transformer Relay_CPRIBLRMUADSASL19TC0005.pdf added

Files

CPRI-CG Power-Transformer Relay_CPRIBLRMUADSASL19TC0005.pdf 243 KB 07/08/2021 Herbert Falk