

# IEC 61850 Certificate - IEC 61850 Certificate #2867

## ZT-SG-100 Signal Generator [KEPCO]

07/08/2021 04:57 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	19-051657-01-1
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	32C8D1FEDE7A2A6A07E58A8B9F373 CBDF9352CE7248C4596B18A74C3793 0288E
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	KEPCO	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	#55 Jeollyeok-ro, Naju-si, Jeollanam-do Republic of Korea, 58217	<b>Umbrella Organization:</b>	
<b>Product:</b>	ZT-SG-100 Signal Generator	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	Linux	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Test Tool	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/29/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-051657-01-1\_KEPCO\_ZT-SG-100\_Server\_Ed2\_Certification\_KTL.pdf added

### Files

19-051657-01-1_KEPCO_ZT-SG-100_Server_Ed2_Certification_KTL.pdf	17 KB	07/08/2021	Herbert Falk
---	-------	------------	--------------