

# IEC 61850 Certificate - IEC 61850 Certificate #2869

## PRS-721 Breaker Protection [CYG SUNRI Co., Ltd.]

07/08/2021 04:57 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 092391 0029 Rev. 00
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	B72CFD44AD6FE66445C7525A6EE3C C44674B78EE86B5FE155FEE2841A48 B729C
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	CYG SUNRI Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 13, Keji North 1st Road, North Area of Hi-Tech Industrial Park, Nanshan District, Shenzhen518057, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	PRS-721 Breaker Protection	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.00	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Measurement, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/29/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-D 092391 0029 Rev. 00-CYG\_PRS-721\_IEC61850Ed2-Server-Certificate.pdf added

#2 - 07/11/2021 11:08 AM - Herbert Falk

- File 19-D 092391 0029 Rev. 00-CYG\_PRS-721\_IEC61850Ed2-Server-Certificate.pdf added

- Address updated

#3 - 07/11/2021 11:08 AM - Herbert Falk

- File deleted (19-D 092391 0029 Rev. 00-CYG\_PRS-721\_IEC61850Ed2-Server-Certificate.pdf)

**Files**

---

19-D 092391 0029 Rev. 00-CYG_PRS-721_IEC61850Ed2-Server-Certificate.pdf	07/11/2021	Herbert Falk
---	------------	--------------