

IEC 61850 Certificate - IEC 61850 Certificate #2870

SPRECON-E-C PAC IED (Gateway, SC, BC) [Sprecher Automation GmbH]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10157161-INC 19-2825
61850 Edition:	Edition 2	Certificate Hash:	2A85E54FD009525A4C000C6DA10962 F7C1BD854B6C774D9EA65A0C2E14C E012D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Sprecher Automation GmbH	Vendor Artifact Hash:	
Address:	FranckstraBe 51 A-4018 Linz, Austria	Umbrella Organization:	
Product:	SPRECON-E-C PAC IED (Gateway, SC, BC)	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	8.64	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/03/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2825_DNVGL_Sprecher_SPRECON-E-C_ClientEd2_Certificate.pdf added

Files

19-2825_DNVGL_Sprecher_SPRECON-E-C_ClientEd2_Certificate.pdf 114 KB

07/08/2021

Herbert Falk