

IEC 61850 Certificate - IEC 61850 Certificate #2872

MFP-H2SB Overcurrent Protection Relay [Mitsubishi Electric Corporation]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10147831-INC 19-2852
61850 Edition:	Edition 1	Certificate Hash:	E065BB962B5A1378D167759B03546A EB1897C024E1A60BAB5AD17B4E61E2 87BA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Umbrella Organization:	
Product:	MFP-H2SB Overcurrent Protection Relay	Optional Reservation Test:	No
HW Version:	667PSA	Serial Number:	
SW Version:	61850:PGKK0310; Relay:PGKZ96	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/23/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2852_DNVGL_Mitsubishi_MFPH2SB_ServerEd1_Certificate.pdf added

Files

19-2852_DNVGL_Mitsubishi_MFPH2SB_ServerEd1_Certificate.pdf	115 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------