

IEC 61850 Certificate - IEC 61850 Certificate #2873

NSD500M4 Bay Control Unit [NARI Technology Co., Ltd.]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10124892-INC 18-3167
61850 Tested Aspects:	Server	Certificate Hash: 9665F7C7C940E98C6240138E862E754 FDCBDA0590D1158432B1B8B1427EA7794
Company:	NARI Technology Co., Ltd.	Vendor Artifact File Name:
Address:	NARI Technology CO., Ltd. No.19, Chengxin Avenue, Jiangning District, 210000, Nanjing, People's Republic of China	Vendor Artifact Hash:
Product:	NSD500M4 Bay Control Unit	Umbrella Organization:
HW Version:	R1.10	Optional Reservation Test: No
SW Version:	6.02.1	Serial Number:
Key Words:	Bay Controller	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/25/2019	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 18-3167_DNVGL_NARI_TECH_NSD500M4_ServerEd2_Certificate.pdf added

Files

18-3167_DNVGL_NARI_TECH_NSD500M4_ServerEd2_Certificate.pdf 25 KB

07/08/2021

Herbert Falk