

IEC 61850 Certificate - IEC 61850 Certificate #2876

HS1902-HMI Substation Automation Operati [HANSHIN ELECTRIC Co.,Ltd.]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19-020639-01-3
61850 Edition:	Edition 1	Certificate Hash:	9E2309530FB41FA668311AE9A92041B 665BB15A12D4E0ABC45A18633E8BC0 8EE
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	HANSHIN ELECTRIC Co.,Ltd.	Vendor Artifact Hash:	
Address:	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	Umbrella Organization:	
Product:	HS1902-HMI Substation Automation Operati	Optional Reservation Test:	No
HW Version:	HP Z4 with Windows Server 2016	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm, HMI	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/23/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-020639-01-3_Hanshin_HS1902-HMI_Client_Ed1_Certification_KTL.pdf added

Files

19-020639-01-3_Hanshin_HS1902-HMI_Client_Ed1_Certification_KTL.pdf 123 KB

07/08/2021

Herbert Falk