

IEC 61850 Certificate - IEC 61850 Certificate #2877

CSC-101-EB Line Distance Protection IED [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10160572-INC 19-2933
61850 Edition:	Edition 2	Certificate Hash:	3B548A5F159D09ECFAD7E5903029E0 B74793C19399563CF2B6DCA549D258 F011
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	No.9, Shangdi Fourth Street Haidian District Beijing 100085 Peoples Republic of China	Umbrella Organization:	
Product:	CSC-101-EB Line Distance Protection IED	Optional Reservation Test:	No
HW Version:	8SF.004.520/V2	Serial Number:	
SW Version:	V1.41	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/28/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2933_DNVGL_Sifang_CSC-101-EB_ServerEd2_Certificate.pdf added

Files

19-2933_DNVGL_Sifang_CSC-101-EB_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------