

IEC 61850 Certificate - IEC 61850 Certificate #2881

MiCOM P40 Agile P442 Distance Protection [GE Renewable Energy]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6442.801
61850 Edition:	Edition 2	Certificate Hash:	D5BC67CF5964124DD3A1D94EBB5A9 7D49615E9CB0F1F32D3FCB04BFEA22 2E191
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	Umbrella Organization:	
Product:	MiCOM P40 Agile P442 Distance Protection	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	91D	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/31/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 50745.6442.801_GE_P442_V91D_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6442.801_GE_P442_V91D_Edition2_Certificate.pdf	266 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------