

IEC 61850 Certificate - IEC 61850 Certificate #2883

MiCOM P40 Agile P143 Feeder Management R [GE Renewable Energy]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6143.801
61850 Edition:	Edition 2	Certificate Hash:	6B1028B8081680A79CC608379E9B925 47D39F3792099AD1A2268D4F931F1A8 34
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	Umbrella Organization:	
Product:	MiCOM P40 Agile P143 Feeder Management R	Optional Reservation Test:	No
HW Version:	P	Serial Number:	
SW Version:	91C	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/31/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 50745.6143.801_GE_P143_V91C_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6143.801_GE_P143_V91C_Edition2_Certificate.pdf	252 KB	07/08/2021	Herbert Falk
------------------------------------------------------	--------	------------	--------------