

IEC 61850 Certificate - IEC 61850 Certificate #2884

MiCOM C434 Bay Unit for Control and Moni [Schneider Electric Industries SAS]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	MiCOM_C434_661-251_Ed2
61850 Edition:	Edition 2	Certificate Hash:	98FAFB363C738FFA2CF49FA0488AD5 92169C06149AE08D6AC3F8AC9BD03B 0DDE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider Electric
Product:	MiCOM C434 Bay Unit for Control and Moni	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	661-251	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/04/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File *SchneiderElectric_MiCOM_C434_661_ServerEd2_Certificate.pdf* added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to *Schneider Electric*

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (*Schneider Electric*)

#4 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to *Schneider Electric*

Files

SchneiderElectric_MiCOM_C434_661_ServerEd2_Certificate.pdf	110 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------