

# IEC 61850 Certificate - IEC 61850 Certificate #2886

## CSC-150-EA-DM Distributed Busbar Protect [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:57 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10160572-INC 19-2939
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	78B3FD7BC217A40B32D73CA8BBB0B B34F599808A79B20DC23201EE442515 A82A
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Beijing Sifang Automation Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No.9, Shangdi Fourth Street Haidian District Beijing 100085 Peoples Republic of China	<b>Umbrella Organization:</b>	
<b>Product:</b>	CSC-150-EA-DM Distributed Busbar Protect	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	8SF.004.519/V1	<b>Serial Number:</b>	
<b>SW Version:</b>	V1.40	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0_rev1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/07/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2939\_DNVGL\_Sifang\_CSC-150-EA\_ServerEd2\_Certificate.pdf added

### Files

19-2939_DNVGL_Sifang_CSC-150-EA_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
-----------------------------------------------------------	--------	------------	--------------