

IEC 61850 Certificate - IEC 61850 Certificate #2887

CSI-200E-G-EBL Bay Control Unit IED [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10160572-INC 19-2936
61850 Edition:	Edition 2	Certificate Hash:	D22DF828ACD7490032BC9A99E895A9 443C3FB2AA23ACA43C794ECB4A81E C2412
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	No.9, Shangdi Fourth Street Haidian District Beijing 100085 Peoples Republic of China	Umbrella Organization:	
Product:	CSI-200E-G-EBL Bay Control Unit IED	Optional Reservation Test:	No
HW Version:	8SF.004.547/V1	Serial Number:	
SW Version:	V1.00	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/07/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:57 PM - Herbert Falk

- File 19-2936_DNVGL_Sifang_CSI-200E-G-EBL_ServerEd2_Certificate.pdf added

Files

19-2936_DNVGL_Sifang_CSI-200E-G-EBL_ServerEd2_Certificate.pdf 116 KB

07/08/2021

Herbert Falk