

# IEC 61850 Certificate - IEC 61850 Certificate #2895

## MiCOM P40 Agile P643 Transformer Protect [GE Renewable Energy]

07/08/2021 04:58 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10175300-INC 19-3207
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	A8D34C654759F46D55E6E34ECEAFE1 E208B50267ABD3473162144790E6339 9DB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Renewable Energy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	<b>Umbrella Organization:</b>	
<b>Product:</b>	MiCOM P40 Agile P643 Transformer Protect	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	M	<b>Serial Number:</b>	
<b>SW Version:</b>	91D	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/22/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3207\_DNVGL\_GE\_MiCOM\_P643\_P642\_ServerEd2\_Certificate.pdf added

### Files

19-3207\_DNVGL\_GE\_MiCOM\_P643\_P642\_ServerEd2\_Certificate.pdf 116 KB

07/08/2021

Herbert Falk