

IEC 61850 Certificate - IEC 61850 Certificate #2896

MiCOM P40 Agile P444 Distance Protection [GE Renewable Energy]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Test Document:
61850 Tested Aspects:	Server	Certificate Name: 10175300-INC 19-3204
Company:	GE Renewable Energy	Certificate Hash: 95745D8AEEB465957D706D851010E657FC79240BF474A1A53BE3031B84B32EEC
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	Vendor Artifact File Name:
Product:	MiCOM P40 Agile P444 Distance Protection	Vendor Artifact Hash:
HW Version:	M	Umbrella Organization:
SW Version:	91D	Optional Reservation Test: No
Key Words:	Distance, Protection, Relay	Serial Number:
Test Procedure Version:	1.0	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	12/22/2019	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	DNV Netherlands (A)	Subscriber Preferred Rates:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3204_DNVGL_GE_MiCOM_P444_P442_ServerEd2_Certificate.pdf added

Files

19-3204_DNVGL_GE_MiCOM_P444_P442_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------