

# IEC 61850 Certificate - IEC 61850 Certificate #2897

## KELMAN DGA 900 Dissolved Gas Analyser [GE Grid Solutions (UK) Ltd]

07/08/2021 04:58 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10174000-INC 19-3184
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	12C726657539C865805B7031AE3C437 910CCBF8C587514C737275D05DBCE2 2D2
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Grid Solutions (UK) Ltd	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Lissue Industrial Estate East Unit 1, 7 Lissue Walk, Lisburn BT28 2LU, County Antrim	<b>Umbrella Organization:</b>	
<b>Product:</b>	KELMAN DGA 900 Dissolved Gas Analyser	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.30.0.2514	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Measurement	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/22/2019	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3184 DNVGL\_GE\_DGA900\_ServerEd2\_Certificate.pdf added

### Files

19-3184 DNVGL_GE_DGA900_ServerEd2_Certificate.pdf	114 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------