

IEC 61850 Certificate - IEC 61850 Certificate #2900

MiCOM AGILE P145 [M/s. GE T&D India Ltd.]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL19TC0007
61850 Edition:	Edition 2	Certificate Hash:	9B1246207136E14AA24B477A12A6A0 C7988CE740B8C1AF4707332274FD16 5AA7
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. GE T&D India Ltd.	Vendor Artifact Hash:	
Address:	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI - 600043 INDIA	Umbrella Organization:	
Product:	MiCOM AGILE P145	Optional Reservation Test:	No
HW Version:	P145-M	Serial Number:	
SW Version:	61	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/06/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File CPRI - GE TD India Ltd - P145-CPRIBLRMUADSASL19TC0007.pdf added

Files

CPRI - GE TD India Ltd - P145-CPRIBLRMUADSASL19TC0007.pdf 1.68 MB

07/08/2021

Herbert Falk