

IEC 61850 Certificate - IEC 61850 Certificate #2902

PSL 641UX [Guo Dian Nanjing Automation Co., Ltd.]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 002427 0003 Rev. 00
61850 Edition:	Edition 1	Certificate Hash:	CC83785DFC83F7194231A944703B737 45904C121F04BC4084047E2C9CFCFC 2D4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Guo Dian Nanjing Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	No.39, Shuige Road, Jiangning Development Zone, 211153, Nanjing, People's Republic of China	Umbrella Organization:	
Product:	PSL 641UX	Optional Reservation Test:	No
HW Version:	GDNZ209701048918	Serial Number:	
SW Version:	5.02.02.10h2	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/06/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-D 002427 0003 Rev. 00_PSL 641UX_IEC61850Ed1-Server-Certificate.pdf added

Files

19-D 002427 0003 Rev. 00_PSL 641UX_IEC61850Ed1-Server-Certificate.pdf 209 KB

07/08/2021

Herbert Falk