

IEC 61850 Certificate - IEC 61850 Certificate #2905

MiCOM P40 Agile P145 Feeder Management R [GE Renewable Energy]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10175300-INC 19-3213
61850 Edition:	Edition 2	Certificate Hash:	6DF02A9E9217E2DE8656466D15A450 6D131A46C7FA7A8EB1720FC740F31F 9F4B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	Umbrella Organization:	
Product:	MiCOM P40 Agile P145 Feeder Management R	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	91C	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/08/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3213_DNVGL_GE_MiCOM_P145_P143_P142_P141_ServerEd2_Certificate.pdf added

Files

19-3213_DNVGL_GE_MiCOM_P145_P143_P142_P141_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk